

कार्यालय, असैनिक शल्य चि० सह मुख्य चिकित्सा पदाधिकारी,
प० चम्पारण, बेतिया

ज्ञाप सं०.....

बेतिया, दिनांक.....

To Whom It May Concern

जिला ईपिडेमियोलॉजिस्ट, जिला स्वास्थ्य समिति, प० चम्पारण, बेतिया द्वारा समर्पित जॉच प्रतिवेदन के आलोक में सरस्वति विद्या मंदिर, हेडगेवार नगर, बरवत सेना, बेतिया का परिसर साफ-सुथरा एवं स्वच्छ पाया गया ।

असैनिक शल्य चि० सह मु० चिकित्सा पदा०
प० चम्पारण, बेतिया

ज्ञाप सं० 102

बेतिया, दिनांक 18/01/21

प्रतिलिपि : प्राचार्य, सरस्वति विद्या मंदिर, हेडगेवार नगर, बरवत सेना, बेतिया को सूचनार्थ प्रेषित ।

ATTESTED
Principal
S.V.M.+2, BETTIAH
Aff. No.-330057

असैनिक शल्य चि० सह मु० चिकित्सा पदा०
प० चम्पारण, बेतिया

Manager
S.V.M., Bettiah.

702

**Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report**

Zone - Muzaffarpur
District Name: West Champaran

Division Name: P.H. Division, Bettiah

Format: I

Sl. No.	Block	Panchayat	Village	Vill age code	Name of Habitation	Location of Source	Latitude	Longitude	Parameters															Remarks	
									pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO ₃	SO ₄	F	As	Total Coli		
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
1	BETTIAH	BARWAT SENA	DR HEDGEWAR NAGAR		DR HEDGEWAR NAGAR	SARASWATI VIDYA MANDIR SCHOOL BETTIAH			7	1	649	422	240	56	20	20	250	0.1	NIL	10	0.6	NOT TESTED	NOT TESTED		
Desirable Limit (mg/l)									6.5-8.5	1.0	-	500	200	75	30	250	200	1.0	45	200	1.00	0.01			
Permissible Limit* in absence of alternate source (mg/l)									NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.50	NR	**		

Analyzed water sample conform to indian standard under permissible limit for drinking purpose

Analyzed water sample conform to Indian standard under permissible limit for drinking purpose

Sample Collected by -- SCHOOL PRINCIPAL SARASWATI VIDYA MANDIR

S. V. M. + 2
Lab Assistant
P.H. Division Bettiah

S. V. M. + 2
18/4/21
Chemist
P.H. Division, Bettiah

ATTESTED
S. V. M. + 2
PRINCIPAL
S.V.M.+2, BETTIAH
Aft. No.-330057

S. V. M. + 2
Manager
S.V.M., Bettiah.